



United States Steel Corporation  
Clairton Works  
400 State Street  
Clairton, PA 15025

July 10, 2006

Dr. Roger C. Westman  
Department of Air Quality  
Bureau of Air Pollution Control  
301 Thirty-Ninth Street  
Pittsburgh, PA 15201

U.S. Environmental Protection Agency  
Region III  
Air, Radiation & Toxics Division  
1650 Arch Street  
Philadelphia, PA 19103-2029  
ATTN: James W. Hagedorn (3AT23)

Assistant Council  
Department of Environmental Protection  
Southwest Region  
400 Waterfront Drive  
Pittsburgh, PA 15222-4745  
ATTN: Steve Hepler

Department of Justice  
Environmental and Natural Resource Division  
Environmental Enforcement Section  
P.O. Box 7611  
Ben Franklin Station  
Washington, D.C. 20044  
ATTN: David Street, Esq.

Subject: USS Reference Number: 06-0225  
ACHD Reference Number: 7718  
600 Carbonate Plant  
USS Clairton Works

Gentlemen:

The attached form terminates the subject incident. Any questions concerning this matter should be referred to Coleen M. Davis at 233-1015.

Sincerely,

Anton Lukac  
Plant Manager  
Clairton Works

NOTICE OF PLANNED OUTAGE OF EQUIPMENT  
ARTICLE XXI - SECTION 2108.1

1. USS Reference Number: 06-0225 Termination  
ACHD Reference Number: 7718
2. Date & Time of Breakdown: Date: 06/12/06 Time: 1040 hours
3. Company Name: U.S. Steel Corporation - USS Clairton Works
4. Specific Equipment Involved or Affected: 600 Carbonate Plant
5. BAPC Permit Number (if applicable):
6. Location: Clairton, PA
7. Nature and cause of breakdown: The 600 Carbonate Plant will be out of service to perform general maintenance.

The 600 Carbonate Unit is a redundant piece of equipment. Gas processing for sulfur removal will be handed off to the 100 Carbonate Unit. Sulfur Plant performance will not be affected. Sulfur emissions will not increase.

8. Identification of Emissions:

- A. Type(s) (CO, NOX, SO<sub>2</sub>, Particulates, Hydrocarbons, etc.)  
The 100 Carbonate Plant will carry the full acid gas flow to the plant. No environmental impact is expected.
- B. Toxic qualities of each type (including its qualities as an irritant, and its potential for causing illness, disability, or mortality). N/A No environmental impact is expected.
- C. Amount of each type emitted (or likely to be emitted).  
N/A

9. Measures taken (or to be taken) to minimize length of breakdown and amount of emissions, including shutdown or curtailment (or why it is impossible or impractical to do so).  
The 100 Carbonate Plant carried the full acid gas flow to the plant.

10. Facility back in operation - Date: 07/07/06 Time: 1200 hours

Signature

Coleen M. Davis

Date

7-11-06

Coleen M. Davis

Senior Environmental Control Engineer Phone: 233-1015